



To: Mountain Regional Water Administrative Control Board Members
From: Brian Davenport
Date: June 2024
Re: Operations Department Update

OVERVIEW OF PAST MONTH

1. We had 1 leak repair this past month. It was in Redhawk. We had 2 hydrants get hit. One has to be replaced in The Enclave, the other was just repaired in the Colony.
2. Crews are doing PRV maintenance in the Colony area. The seasonals are working on hydrants and valves in Promontory.
3. Sun Peak well 2 is up and running in our system at about 90 gpm.
4. Old Ranch pump station upgrades are continuing. A Nitrogen system is installed and the ceiling is being refurbished.
5. Well 2 in Summit Park and the Gulch Well at the Canyons were both pulled. Working on brush and bail and also scheduled to be videoed. Well 5 pump and motor in Summit Park was installed and ready to go if needed. It was also brushed,bailed and videoed. (See pic)
6. The Jailhouse well's power was hit by a contractor in the area. Working on repairs.

FOCUS FOR NEXT MONTH:

1. Old Ranch pump station improvements-continue with concrete work and ceiling refurbishment.
2. PRV maintenance is ongoing in the Colony area. We have 23 stations in the Colony.
3. Well repairs.
4. Continue with the upsizing of the culinary water piping at the treatment plant.

